



HGL0800AW----				
Components	1S0000	1C0000	1S*000	1C*000
Line Reactor (LR)	X	X	X	X
Trap Reactor (TR)	X	X	X	X
Capacitor (Cap)	X	X	X	X
Trap Fusing, FU1, FU2, FU3	X	X	X	X
Contactor (CNT)		X		X
Transformer (XFMR)	X	X	X	X
XFMR Fusing, FU4, FU5	X	X	X	X
PQConnect Board			X	X

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
F	6266, KDRY3TT to KDRX3STT	5/10/2023	DSW	DECIMAL
E	6024 Add PQ Option	8/26/22	JTL	.XX ± .25 .XXX ± .10
D	5653, GE to ABB CNT CHG.	1/31/2022	DSW	FRACTIONAL
C	5554 Updated Trap, Weights, DB	04/05/21	JRN	± 1/16
B	Add PQ Connect	3/12/19	DSW	ANGULAR
NO	REVISION	DATE	BY	± 1°

DRN BY: DSW	DATE: 10/13/17	REV: 107276DG
SCALE: 1/8	DRVD: HGL	SIZE: C

W182N10611 (Rev 13 Feb 2022)
Germerman, WI 53022
© 2022 TCI, LLC
An Official Motion Controls Company
Harmonic Guard Low Capacitance
HGL, 800HP, 480/3/60, Type 1
SHT 1 OF 1