


HGP Part Number	HorsePower (HP)	kVar	Harmonic	Voltage (V)	Hz.	Phase
HGP0060CW3----	60	20	5th	600	60	3
HGP0075CW3----	75	25	5th	600	60	3

HGP Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0060CW3S0000	29474-4	259
HGP0060CW3C0000	29474-5	261
HGP0060CW3C000H	29475-6	265
HGP0060CWCS1000	29474-PQ1	261
HGP0060CW3C1000	29474-PQ	263
HGP0060CW3C100H	29474-PQH	267

HGP Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0075CW3S0000	29474-4	269
HGP0075CW3C0000	29474-5	271
HGP0075CW3C000H	29474-6	275
HGP0075CWCS1000	29474-PQ1	271
HGP0075CW3C1000	29474-PQ	273
HGP0075CW3C100H	29474-PQH	277



Components	HGP0060CW3----		HGP0075CW3----			
	S0000	C0000	C000H	S1000	C1000	C100H
Line Reactor (LR)	x	x	x	x	x	x
Trap Reactor (TR)	x	x	x	x	x	x
Capacitor (Cap)	x	x	x	x	x	x
Trap Fusing, FU1, FU2, FU3	x	x	x	x	x	x
Contactor (CNT)		x	x		x	x
Transformer (XFMR)	x	x	x	x	x	x
XFMR Fusing, FU4, FU5	x	x	x	x	x	x
Heater			x			x
PQConnect Board				x	x	x

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.					TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10	TCI W132 N10611 Grant Drive Germantown, WI 53022 HarmonicGuard Passive HGP, 60HP, 75HP, 600/3/60, Type 3R
	B	S265, Update Enclosure	8/4/2020	DSW	FRACTIONAL ± 1/16	
	A	Note was drawing 105904	8/31/18	DSW	ANGULAR ± 1°	
	NO	REVISION	DATE	BY	SCALE: 1/8	

DRN BY: DSW	DATE: 2/10/15	105531DG
SCALE: 1/8	DRIVE	REV: C